

# ZERTIFIKAT

**Zertifikatinhaber** Nupi Industrie Italiane S.p.A.  
Via Stefano Ferrario, 8  
21052 Busto Arsizio VA  
ITALIEN

**Herstellwerk** Castel Guelfo (BO)

**Produkt** Druckrohre aus Polyethylen (PE) für alternative Verlegetechniken - PE 100-RC

**Klassifizierung** EG 926.1, Außen-Durchmesser 32 x 3,0 mm bis 63 mm

**Typ, Modell** NUPI NADIR PLUS

**Erläuterungen zum Typ** PAS 1075 Typ 1 - TW  
Basis EN 12201-2

**Prüfgrundlage(n)** PAS 1075:2009-04  
Zertifizierungsprogramm Kunststoffrohrsysteme (Druckrohre und -formstücke)  
(2015-03)

**Konformitätszeichen**



**Registernummer** P1R0456

**Gültig bis** 2021-04-30

**Nutzungsrecht** Dieses Zertifikat berechtigt zum Führen des oben stehenden Konformitätszeichens in Verbindung mit der genannten Registernummer.  
Weitere Angaben siehe Anhang.

2016-04-26  
Dipl.-Wi.-Ing. (FH) Sören Scholz  
Leiter der Zertifizierungsstelle

*S. S.*



# ANHANG

Seite 1 von 1

<b>Zertifikat</b>	P1R0456 von 2016-04-26
<b>Technische Angaben</b>	Werkstoff: PE 100-RC Werkstofftyp: siehe produktionsstättenbezogene Werkstoffliste Abmessungen: Außen-Durchmesser: 32 - 40: SDR 11, SDR 7,4 Abmessungen: Außen-Durchmesser: 50 - 63: SDR17, SDR 11, SDR 7,4 Betriebsüberdruck Berstlining: max. 5 bar (SDR 11) Farbe: schwarz mit royal blauen Streifen
<b>Prüflaboratorium/ Überwachungsstelle</b>	Hessel Ingenieurtechnik GmbH Am Münsterwald 3 52159 Roetgen
<b>Prüfbericht(e)</b>	R16 01 3003-A_(PLT+) von 2016-04-21



# CERTIFICATE

<b>Certificate holder</b>	<b>Nupi Industrie Italiane S.p.A.</b> <b>Via Stefano Ferrario, 8</b> <b>21052 Busto Arsizio VA</b> <b>ITALY</b>
<b>Production facility</b>	Castel Guelfo (BO)
<b>Product</b>	Pipes made from Polyethylene for alternative installation techniques - PE 100-RC
<b>Classification</b>	EG 926.1, Outside Diameter 32 x 3.0 mm to 63 mm
<b>Type, Model</b>	NUPI NADIR PLUS
<b>Remarks to the type</b>	PAS 1075 Type 1 - TW Basis EN 12201-2
<b>Testing basis</b>	PAS 1075:2009-04 Certification Scheme Plastic pipe system (pressure pipes and fittings (2015-03)

**Mark of conformity****Registration No.** P1R0456**Valid until** 2021-04-30**Right of use** This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.  
See annex for further information.

2016-04-26

S. Scholz  
Dipl.-Wi.-Ing. (FH) Sören Scholz  
Head of Certification Body

# ANNEX

Page 1 of 1

**Certificate**

P1R0456 dated 2016-04-26

**Technical Data**

Material: PE 100-RC

Type: see production facility related material list

Dimensions: Outside diameter: 32 - 40: SDR 11, SDR 7.4

Dimensions: Outside diameter: 50 - 63: SDR 17, SDR 11, SDR 7.4

Operating pressure Berstlining: max. 5 bar (SDR 11)

Colour: black with royal blue stripes

**Testing laboratory/  
Inspection body**

Hessel Ingenieurtechnik GmbH  
Am Münsterwald 3  
52159 Roetgen  
GERMANY

**Test report(s)**

R16 01 3003-A\_(PLT+) dated 2016-04-21

